

GHGT-16, Lyon, 25.10.2022

Techno-economic Evaluation of Oxyfuel CO₂ Capture in Two European Cement Plants

Mari Voldsund^a, Rahul Anantharaman^a, Leif E. Andersson^a, Francisco Carrasco^b, Kristina Fleiger^c, Paul Jourdaine^d, Laurent Mariac^e, <u>Simon Roussanaly</u>^a, Avinash Subramanian^a, Ines Veckenstedt^f, and Mirko Weber^g

^aSINTEF Energy Research, ^bHeidelbergMaterials, ^cVDZ Technology gGmbH, ^dAir Liquide, ^eTotalEnergies, ^fthyssenkrupp Industrial Solutions AG, ^gHolcim Technology Ltd




The AC²OCem project

- ACT-project
- 11 European partners
- Coordinator: University of Stuttgart
- 2019 2023
- 4.3 M€
- Demo tests, theoretical and analytical studies
 - -> expedite large scale implementation of 1st generation oxyfuel for retrofit
 - -> promote a novel oxyfuel concept for new-built plants




11. Total Norge AS, Norway












Lägerdorf (Germany) Holcim 4400 tonne clinker/day 20% raw material moisture

German el mix 2019: 77 €/MWh (Eurostat) 10 kg CO₂/MWh (Statista)





Slite (Sweden) HeidelbergCement 5600 tonne clinker/day 2-3% raw material moisture

Swedish el mix 2019: 44 €/MWh (Eurostat) 344 kg CO₂/MWh (Statista)

Figure: Google maps




Increased levelized cost of clinker:

$$\Delta LCOC = LCOC_{CCS} - LCOC_{ref} = \left(\frac{\sum_{t=1}^{n} (CAPEX_t + OPEX_t)(1+r)^{-t}}{\sum_{t=1}^{n} A_{cli,t}(1+r)^{-t}}\right)_{CCS} - \left(\frac{\sum_{t=1}^{n} (CAPEX_t + OPEX_t)(1+r)^{-t}}{\sum_{t=1}^{n} A_{cli,t}(1+r)^{-t}}\right)_{ref}$$

Cost of CO₂ avoided without transport and storage:

$$CAC = \frac{\Delta LCOC}{e_{clk,eq,ref} - e_{clk,eq,CCS}}$$









Economic parameter	Value
Cost year	2019
Discount rate	8%
Years of construction	1
Lifetime	25



VDZ simulation of core process with in-house cement plant model



SINTEF heat integration for design of heat exchanger networks





Space availability and location of equipment

Unit	Slite	Lägerdorf
Oxygen pipeline (Kiln system – ASU)	800 m	510 m
Flue gas pipeline (Gas recirculation – CPU)	700 m	220 m
Liquid CO_2 pipeline (CO_2 storage tanks – loading facility)	600 m	410 m



Slite: Limited space available close to kiln line. Existing old kiln must be removed.

> Lägerdorf: More available space close to kiln line.



Photo: Google maps

Photo: Google maps



- ASU and CPU: AirLiquide
- Flue gas recycling and plant modifications: thyssenkrupp Industrial Solutions (high-level estimate based on project planning archive from previous projects)
- Additional heat recovery: SINTEF
- Ducting and CO₂ storage tanks: TotalEnergies
- Removal of existing equipment: HeidelbergCement and Holcim



	Clinker production		CO₂ capture	
	Utilisation	Operating	Utilisation	Operation
	factor	hours	factor	hours
Normal operation	91%	8000 h	91%	8000 h
Year 1	50%	4380 h	0%	0 h
Year 2	80%	7008 h	65%	5694 h
Year 3	91%	8000 h	80%	7008 h


Normal operation: Assumed based on typical industry target (not real data from the specific plants)

Year 1-3:

- Downtime necessary for plant modifications estimated by thyssenkrupp IS (6 months)
- Unforeseen downtime assumed




Increased levelized cost of clinker (ΔLCOC)



- Main cost drivers:
 - Core process CAPEX
 - CPU CAPEX
 - Oxygen (TCO)
 - Electricity
- Main plant differences:
 - Heat recovery required
 - Location factor
 - Space availability
 - Electricity and oxygen price






- Costs related to lost productionOther variable OPEX
- Electricty (w/o ASU consumption)
- Oxygen
- Fixed OPEX labour costs
- Fixed OPEX maintenance costs
- Fixed OPEX insurance and location tax
- CAPEX Other
- CAPEX CO2 storage
- CAPEX Ducting
- CAPEX CPU
- CAPEX Core process
- Total

- Direct and indirect emissions are considered
- Lägerdorf higher CO₂ avoided than Slite due to a different process




CAC sensitivity to electricity price and CO₂ intensity (includes impact of electricity price on oxygen cost)



CAC sensitivity to CAPEX




CAC sensitivity to downtime




- Downtime is a major uncertainty
 - Clinker production downtime
 - CO₂ capture downtime with clinker production
- Lost production of clinker has largest impact on CAC




Without steam cycle



With steam cycle, 8.7 MW power








- Increased CAPEX
- Reduced electricity cost
- Increased CO₂ avoided
- Base case: Sweden 2019
 - Electricity price: 44 €/MWh
 - CO₂ emission factor: 10 kg/MWh

Slite heat to power cycle – sensitivity to grid conditions



SINTEF

- Slite without power cycle
- 0 kg/MWh
- ---- 400 kg/MWh
- Slite with power cycle
- 0 kg/MWh
- ---- 400 kg/MWh

- Base case: Sweden 2019
 - Electricity price: 44 €/MWh
 - CO₂ emission factor: 10 kg/MWh
- Germany 2019:
 - Electricity price: 77 €/MWh
 - CO₂ emission factor: 344 kg/MWh
- Sweden 2021 S2:
 - Electricity price: 72 €/MWh
- Germany 2021 S2:
 - Electricity price: 131 €/MWh



Comparison with previous studies

Estimate	Cost year	CAC [€/tonne CO ₂]
AC2OCem Slite	2019	67
AC2OCem Lägerdorf	2019	83
CEMCAP	2014	42
ECRA	2009	45

A combination of several factors gives significantly higher CAC than in previous studies • Higher CAPEX

- Real plants considered instead of hypothetical reference plant
- Increased understanding on complexity of modifying existing plants (core process CAPEX)
- Higher CPU CAPEX based on estimate by technology supplier
- Extended scope: pipelines and CO_2 buffer tanks are included
- Plant downtime included
- Higher O₂ consumption in real plants compared to reference plant
- Slightly different evaluation frameworks in the three studies (e.g. contingency estimation)
- Other differences: Location factors, cost years, electricity cost and CO_2 footprint

Note: Due to differences in assumptions, scope, and evaluation framework, costs of other technologies evaluated in CEMCAP cannot be directly compared with AC2OCem oxyfuel costs.



- The main cost drivers for the oxyfuel process are CAPEX and cost of electricity both are sensitive to the specific plant investigated
- Integration of steam cycle may be profitable for plants with low raw material moisture and high electricity prices
- The estimated costs for the two real plants are significantly higher than for the hypothetical reference plant investigated in previous studies





AC²OCem is funded through the ACT program (Accelerating CCS Technologies, Horizon2020 Project No 299663).

Financial contributions made from the, •Research Council of Norway, (RCN), Norway •Federal Ministry for Economic Affairs and Energy (BMWi), Germany •Swiss Federal Office of Energy (SFOE), Switzerland •General Secretariat for Research and Development (GSRT), Greece •French Environment & Energy Management Agency (ADEME), France are gratefully acknowledged.




Supported by:

Federal Ministry for Economic Affairs and Energy

on the basis of a decision by the German Bundestag





Swiss Federal Office of Energy SFOE



2014 - 2020



GENERAL SECRETARIAT FOR RESEARCH AND TECHNOLOGY





Technology for a better society